

Report

Page 1 (7)



T1725700

6ZWHPWS8AZ



Date received 2017-09-21
Issued 2017-10-04

Matis ohf
Hrólfur Sigurdsson
Food Research, inn. and safety
Vinlandsleid 12
IS-113 Reykjavik
Iceland

Project
Reference

Analysis of drinking water

Your ID	R17-2510-1/AS-1 çorlákshöfn, Norðurbyggð 22b						
LabID	O10924888						
Analysis	Results	Uncertainty (±)	Unit	Method	Issuer	Sign	
Ca	6.17	0.47	mg/l	1	R	ERJA	
Fe	0.000470	0.000464	mg/l	1	H	ERJA	
K	0.786	0.059	mg/l	1	R	ERJA	
Mg	2.59	0.17	mg/l	1	R	ERJA	
Na	11.1	0.8	mg/l	1	R	ERJA	
Si	8.39	0.52	mg/l	1	R	ERJA	
Al	11.1	2.0	µg/l	1	H	ERJA	
As	0.0700	0.0174	µg/l	1	H	ERJA	
Ba	0.154	0.029	µg/l	1	H	ERJA	
Cd	0.00358	0.00133	µg/l	1	H	ERJA	
Co	<0.005		µg/l	1	H	ERJA	
Cr	0.338	0.066	µg/l	1	H	ERJA	
Cu	0.171	0.052	µg/l	1	H	ERJA	
Hg	<0.002		µg/l	1	F	ERJA	
Mn	0.177	0.058	µg/l	1	H	ERJA	
Mo	0.126	0.024	µg/l	1	H	ERJA	
Ni	<0.05		µg/l	1	H	ERJA	
P	20.0	4.3	µg/l	1	H	ERJA	
Pb	<0.01		µg/l	1	H	ERJA	
Sr	8.63	0.87	µg/l	1	R	ERJA	
Zn	0.261	0.121	µg/l	1	H	ERJA	
V	9.47	1.72	µg/l	1	H	ERJA	
Sb	<0.01		µg/l	2	H	ERJA	
B	<10		µg/l	2	R	ERJA	
S	1.35	0.09	mg/l	2	R	ERJA	
Se	<0.5		µg/l	2	H	ERJA	
benzene	<0.20		µg/l	3	1	VITA	
toluene	<0.20		µg/l	3	1	VITA	
ethylbenzene	<0.10		µg/l	3	1	VITA	
m,p-xylene	<0.20		µg/l	3	1	VITA	
o-xylene	<0.10		µg/l	3	1	VITA	
xylenes, sum*	<0.15		µg/l	3	1	VITA	
dichloromethane	<2.0		µg/l	4	1	VITA	
1,1-dichloroethane	<0.10		µg/l	4	1	VITA	
1,2-dichloroethane	<0.50		µg/l	4	1	VITA	
trans-1,2-dichloroethene	<0.10		µg/l	4	1	VITA	
cis-1,2-dichloroethene	<0.10		µg/l	4	1	VITA	
1,2-dichloropropane	<1.0		µg/l	4	1	VITA	
tetrachloromethane	<0.10		µg/l	4	1	VITA	
1,1,1-trichloroethane	<0.10		µg/l	4	1	VITA	

ALS Scandinavia AB
Box 700
182 17 Danderyd
Sweden

Web: www.alsglobal.se
E-mail: info.ta@alsglobal.com
Tel: + 46 8 52 77 5200
Fax: + 46 8 768 3423

The document is approved and
digitally signed by

Viktoria Takacs

ALS Scandinavia AB
Client Service
viktoria.takacs@alsglobal.com

2017.10.04 10:42:12